

Telephone (609) 588-0011
LECO LABORATORY
3123 Klockner Road
Trenton, New Jersey 08690
Laboratory I.D. # NJ11106

CYO of Mercer County
920 South Broad Street
Trenton, NJ 08611

Date Collected: **3-16-2021**
Time Collected: **8:30am**

Matrix: **Water**
Source: **Church Child Care Area**
Point of Collection: **Boy's Lavatory Sink**
Sampled by: **Owner**
Analysis By: **Certified Lab ID # NJ03886**
LECO Sample #: **L0752111**

| Parameter/Method | Limit | Result |
|-----------------------------|--------------|---------------|
| Lead (SM 3113B) | 0.015 mg/L | <0.002 mg/L |
| Copper (SM 3111B) | 1.30 mg/L | <0.10 mg/L |

> = greater than < = less than

Remarks:

Both parameters tested meet the requirement established by the NJDEP.

Date: **March 23, 2021**

Donald B. Lilley
By: _____
Donald B. Lilley/Director