

Telephone (609) 588-0011
LECO LABORATORY
3123 Klockner Road
Trenton, New Jersey 08690
Laboratory I.D. # NJ11106

CYO of Mercer County
920 South Broad Street
Trenton, NJ 08611

Date Collected: **3-16-2021**
Time Collected: **8:30am**

Matrix: **Water**
Source: **Church Child Care Area**
Point of Collection: **Water Fountain**
Sampled by: **Owner**
Analysis By: **Certified Lab ID # NJ03886**
LECO Sample #: **L0752112**

Parameter/Method	Limit	Result
Lead (SM 3113B)	0.015 mg/L	<0.002 mg/L
Copper (SM 3111B)	1.30 mg/L	<0.10 mg/L

> = greater than < = less than

Remarks:

Both parameters tested meet the requirement established by the **NJDEP**.

Date: **March 23, 2021**

By: *Donald B. Lilley*
Donald B. Lilley/Director