

Telephone (609) 588-0011  
**LECO LABORATORY**  
3123 Klockner Road  
Trenton, New Jersey 08690  
Laboratory I.D. # NJ11106

**CYO of Mercer County**  
**920 South Broad Street**  
**Trenton, NJ 08611**

Date Collected: **3-16-2021**  
Time Collected: **8:37am**

Matrix: **Water**  
Source: **Church Child Care Area**  
Point of Collection: **Classroom # 1 Sink**  
Sampled by: **Owner**  
Analysis By: **Certified Lab ID # NJ03886**  
LECO Sample #: **L0752116**

<b>Parameter/Method</b>	<b>Limit</b>	<b>Result</b>
<b>Lead</b> (SM 3113B)	0.015 mg/L	0.009 mg/L
<b>Copper</b> (SM 3111B)	1.30 mg/L	0.13 mg/L

> = greater than      < = less than

Remarks:

**Both parameters** tested meet the requirement established by the **NJDEP**.

Date: **March 23, 2021**

*Donald B. Lilley*  
By: \_\_\_\_\_  
**Donald B. Lilley/Director**